



COMMUNITY RISK REDUCTION

835 N Central Ave
Tracy, CA 95376
(209) 831-6707

Fire Alarm New Install/T.I. Submittal Requirements

Plan Requirements:

1. Fire Prevention Division Certification of Compliance Form (COC)
2. Construction Plans – full set of detailed must include the following at minimum:
 - a) Engineers stamp
 - b) Occupancy classification
 - c) Symbol legend
 - d) Point of compass
 - e) Single line riser diagram
 - f) Wiring Diagram
 - g) Sequence of operation matrix
 - h) Scope of work
 - i) Codes plans are designed too
 - j) Note describing the degree the building is protected by automatic sprinklers:
 - Not sprinklered
 - Partially (Not Fully sprinklered)
 - Fully (100%) Sprinklered
3. Battery Calculations (3 or more devices)
4. Cover letter describing the degree the building is protected by automatic sprinklers:
 - Not sprinklered
 - Partially (Not Fully sprinklered)
 - Fully (100%) Sprinklered
5. Product data sheets (cutsheets)
6. California State Fire Marshal Office product listing documentation

Inspection required:

1. 24-hour battery ring out before inspection – only new panel and communications
2. Final Inspection (Acceptance test)