



# COMMUNITY RISK REDUCTION

835 N Central Ave  
Tracy, CA 95376  
(209) 831-6707

## County Ground Mount Solar Submittal Requirements

### Plan Requirements:

1. Fire Prevention Division Certification of Compliance Form (COC)
2. Construction Plans
  - a) 10 ft clearance from brush
  - b) KW must be listed on cover page
  - c) Include a warning label page
  - d) Diagram layout of system
3. Site Plan - showing the location of all structures, driveways, water sources, and gates.
  - a) Driveway length, width, and material type (e.g., asphalt, compacted gravel, concrete).
  - b) Indicate all gates crossing any driveway and whether the gate is Manual or Electric (Gate opening width must be minimum 20 ft)
  - c) Knox Box or Knox Padlock Location for after-hours emergency access to site. (if applicable)
4. Product data sheets (cutsheets)

### Inspection required:

1. Fire Final Inspection